

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3266-0013:005 Page 1 of 1

**CATEGORY:** Door Operators

**LISTEE:** Horton Automatics, 4242 Baldwin Blvd., Corpus Christi TX 78405  
Contact: \*John Cringole (361) 888-5591 Fax (361) 888-6510

**DESIGN:** Model 5900 series swinging fire door operator. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation and UL label.

**APPROVAL:** Listed as a door operator for interior locations employing fire-rated doors mounted in pairs. For use in conjunction with approved fire exit hardware employing vertical rod devices on each door, fire door frame and listed smoke detector connected to the electrical control system. Provisions for use with central smoke and/or heat detection system also available.

**NOTE:** Formerly 3265-0013:005

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager